

Zertifikat Certificate



Zertifikat Nr. Certificate No.
R 50224964

Blatt Page
0001

Ihr Zeichen Client Reference
453106

Unser Zeichen Our Reference
ZJL-CSH- 12023917 001

Ausstellungsdatum
28.06.2012

Date of Issue
(day/month/year)

Genehmigungsinhaber License Holder


Swallow Electric Co., Ltd.
2-6-32 Kuwazu, Higashi-Sumiyoshi-ku
Osaka-shi, Osaka
546-0041 JAPAN

Fertigungsstätte Manufacturing Plant

Swallow Electric Co., Ltd.
1-10-5 Mokuzai-Doori, Mihara-ku
Sakai-shi, Osaka
587-0042 JAPAN

Prüfzeichen Test Mark

Geprüft nach Tested acc. to
EN 61558-2-4:2009



Zertifiziertes Produkt (Geräteidentifikation)
Certified Product (Product Identification)

Lizenzentgelte - Einheit
License Fee - Unit

Trenntransformator Isolating Transformer

Type Designation: CE-xEN

x = 100, 200, 300, 500, 750, 1000,
1500, 2000, 2500, 3000, 4000, 5000

6

Rated Supply Voltage: AC 200/220/230/240 V

Rated Output Voltage: AC 100/110/120 V

Protection Class : for use in Class II equipment

Ambient Temperature : max. 50 °C

Rated Output Current:

0,83 A (x=100)	1,7 A (x=200)	2,5 A (x=300)
4,2 A (x=500)	6,3 A (x=750)	8,3 A (x=1000)
12,5 A (x=1500)	16,7 A (x=2000)	20,8 A (x=2500)
25,0 A (x=3000)	33,3 A (x=4000)	41,7 A (x=5000)

Required Protective Device: circuit breaker, Ie as marked
or indicated in Appendix 1

6

ANLAGE (Appendix): 1

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht.

This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.

TÜV Rheinland LGA Products GmbH - Tillystraße 2 - 90431 Nürnberg

Tel.: (+49/221)8 06 - 13 71 e-mail: cert-validity@de.tuv.com

Fax: (+49/221)8 06 - 39 35 http://www.tuv.com/safety

Zertifizierungsstelle

Dipl.-Ing. (FH) J. Taylor

